

Praxis Automation Technology B.V.
Attn.: Mr. S. van Ruiten
Willem Barentszstraat 1-5
2315 TZ LEIDEN

Det Norske Veritas B.V.
Region Northern Europe & Africa
Maritime Serv./Product Certification
Haastrechtstraat 7
3079 DC Rotterdam
P.O. Box 9599
3007 AN Rotterdam
Tel. +31-(0)10 29 22 673
Fax. +31-(0)10 47 96 154
KvK. Reg.No. 24171900
<http://www.dnv.nl>
E-mail: product-certification@dnv.com

Your ref.: Our ref.: 2004_10\AAFAADWN

Rotterdam,
13 October 2005

**Re: TYPE APPROVAL CERTIFICATE A-9372
CERTIFICATION OF STANDALONE MEGA-GUARD-PMS**

Dear Mr. Van Ruiten,

Reference is made to DNV type approval certificate A-9372.



Please be informed as follows, in case that Praxis Automation Technology B.V. supplies the Mega-Guard-PMS as standalone unit and without other components/systems listed in TA-A-9372, we agree to that certification at your works can be waived, under the following conditions.

- That the testing of the units will be carried out by the switch board manufacturer according to your test program. Please note that the test program is to include testing of the items as per DNV rules Part4 Chapter 8 Section 2 B 105
- Or, that the testing of the units will be carried out by the yard on board the vessel in question. Please note that the test program is to included testing of the items as per DNV rules Part 4 Chapter 8 Section 2 B 105

The above testing shall be witnessed by a DNV surveyor.

Yours faithfully,
for DET NORSKE VERITAS B.V.

F.C. Hagenaar
Head of Section
Product Certification



J.A.S. Melsted
Pr. Surveyor